

1
2 **CITY OF COVINGTON**
3 **STATE OF LOUISIANA**
4

5 **RESOLUTION NUMBER 2025-05**
6

7 **A RESOLUTION OF THE CITY OF COVINGTON COUNCIL**
8 **INFORMING THE LOUISIANA DEPARTMENT OF**
9 **ENVIROMENTAL QUALITY OF THE ACTIONS REGARDING**
10 **THE SEWERAGE TREATMENT FACILITY**
11 **(MWPP)**

12 **WHEREAS**, each year the City of Covington is required by our DEQ
13 discharge permits to complete the annual MWPP Audit on the City's sewerage
14 treatment facility.

15 **NOW, THEREFORE, BE IT RESOLVED** by the City of Covington in
16 due, regular, and legal session convened, that the Covington City Council hereby
17 informs Louisiana Department of Environmental Quality that the following actions
18 were taken by the City Council for the City of Covington, Louisiana:


- 19 1. Reviewed the Municipal Water Pollution Prevention Environmental Audit
20 Report which is attached to this resolution.
- 21 2. Set forth the following actions necessary to maintain permit requirements
22 Contained in the Louisiana Water Discharge Permit System (LPDES)
23 number LA0084336
- 24 a. Continue to provide certified operators for operation and provide 16
25 Hours of training per operator during a two-year interval. This training
26 will be conducted through off-site classes and with the assistance of
27 Curtis Environmental Services, Inc.
- 28 b. Maximize aeration to system by maintaining existing equipment,
29 Maintaining spare parts inventory an providing extra aeration when
30 required.
- 31 c. Monitor Influent testing for elevated BOD/TSS results.
- 32 d. Continue review of non-domestic customer surveys and establish a
33 non-domestic user ordinance. Permit all identified non-domestic users
34 through modification of existing sewer ordinance.
- 35 e. Continue Mercury minimization program, provide DEQ annual data
36 reports on program status and complete annual consumer notifications.
37
38
39
40
41

- 1 f. Follow the LPDES Sludge Permit requirements for bio-solids
2 disposal.
3
4 g. Comply with DEQ lab certification and QA/QC monitoring
5 procedures.
6
7 h. Continue to sample and analyze sanitary Influent for the MWPP
8 Annual Audit.
9
10 i. Complete review of potential Plant upgrades.
11
12 j. Continue to upgrade collection system to minimize system overflows.
13

14 **MOVED FOR ADOPTION** by Botsford, seconded by Leeks, was
15
16 then submitted to a vote, the vote thereon being as follows:

17
18 YAYS: 7 ABSENT: 0
19 NAYS: 0 ABSTAIN: 0

20
21 And the resolution was declared adopted on this, the 11th day of
22
23 March, 2025.

24
25
26 /s/ 
27 MARK W. VERRET
28 COUNCIL PRESIDENT

29
30
31 /s/ 
32 JOANN D. RUCKER
33 COUNCIL CLERK

34 CERTIFICATE

35 I, JoAnn D. Rucker, Council Clerk of the City of Covington, certify that
36 the above and foregoing constitutes a true and correct copy of a Resolution passed
37 and adopted by the City of Covington on the 11th day of March 2025, at which
38 meeting a quorum was present and voting.

39 Covington, Louisiana, this 11th day of March. 2025

40
41

/s/ 
JOANN D. RUCKER
COUNCIL CLERK